



City of Roswell

**ADDENDUM "ONE" ITB-22-011**

DATE: November 2, 2021  
TO: Bidders  
PROJECT: **North Garden Sewer Replacement**

NOTICE TO BIDDERS: The following addendum shall be incorporated into the Bid for the above referenced project. This addendum must be acknowledged in the space provided within your submission to **ITB-22-011** on the "**BID ACKNOWLEDGEMENT**" included with the **City of Roswell Bid documents** on **page 22**. Failure to acknowledge can deem your bid as non-responsive and will be returned.

**Q 1: CAN THE CITY INCREASE THE ALLOTTED DAYS ON THIS PROJECT TO A MINIMUM OF 40 WORKING DAYS? TO COMPLETE THIS PROJECT IN 25 WORKING DAYS WOULD REQUIRE A SIGNIFICANT AMOUNT OF OVER-TIME AND AN INCREASED COST TO THE CITY.**

**A 1: THE CITY WILL INCREASE THE WORKING DAYS TO 45 WORKING DAYS.**

**Q 2: IS THERE A SPECIAL PERMIT REQUIRED OR SPECIAL REQUIREMENTS THAT HAVE TO BE MET TO ACCESS ABOVE MENTIONED JOB FOR OUR EMPLOYEES?.**

**A 2: PROJECT WILL BE ON A CITY OF ROSWELL STREET, N. GARDEN AVE. NO SPECIAL PERMIT TO ACCESS, BUT CONTRACTOR WILL HAVE TO FURNISH AND SUBMIT A TCP (TRAFFIC CONTROL PLAN) FOR REVIEW AND APPROVAL BY CITY ENGINEER. CONTRACTOR SHALL FURNISH DEVICES, MAINTAIN DEVICES, TRAFFIC CONTROL DIARY AND TCP THROUGHOUT THE LIFE OF THE PROJECT. THIS WILL BE PAID UTILIZING BID ITEM 702810 TRAFFIC CONTROL DEVICES FOR CONSTRUCTION.**

**OTHER SPECIAL REQUIRMENT – CONTRACTOR SHALL MAINTAIN SEWER MAIN IN SERVICE, IE: BY-PASS PUMPING. ALL EXCAVATION SHALL MEET OSHA REQUIREMENTS.**

**Q 3: CAN YOU ELABORATE ON TRAFFIC CONTROL NEEDS AND EXPECTATIONS?**

**A 3: CONTRACTOR IS REQUIRED TO SUBMIT TRAFFIC CONTROL PHASING TO MATCH PROPOSED CONSTRUCTION PHASING TO BE SUBMITTED. CONTRACTOR MAY REQUEST TO CLOSE THE ROAD TO THROUGH TRAFFIC, BUT PHASES CAN NOT EXCEED MORE THAN TWO BLOCKS AT A TIME. FOR EXAMPLE CONTRACTOR CAN WORK BETWEEN 3 MANHOLES WITH REMOVAL AND REPLACEMENT OF SEWER LINE. CONTRACTOR MUST COMPLETE WORK UP TO COMPLETE FLOWFILL AND PAVEMENT REPAIR BEFORE NEXT SECTION OF WORK CAN PROCEED. FOR EVERY SECTION CONTRACTOR COMPLETES AS EXPECTED, CONTRACTOR MAY BEGIN ANOTHER SECTION.**

**N. GARDEN AVE IS A MAJOR ARTERIAL STREET INCLUDING SCHOOL BUS ROUTE AND CONTRACTOR MUST BE EXPEDITIOUS IN CONSTRUCTION EFFORTS. ROSWELL LIVESTOCK AUCTION AND SALES IS A YEAR ROUND LOCAL BUSINESS THAT MUST ALSO BE COORDINATED WITH.**



City of Roswell

**A.**

**CLARIFICATION OF A SPECIAL NEED FOR ROSWELL LIVESTOCK AUCTION SALES SEWER CONNECTION. AT APPROXIMATELY 33+75 LEFT, CONTRACTOR SHALL REBUILD EXISTING 4" SEWER SERVICE FROM SEWER MAIN TO APPROXIMATELY 66 FEET WEST TO EXISTING CLEAN OUT. THIS WORK SHALL BE INCLUDED AS PART OF ITEM 663944 ITEM SANITARY SEWER SERVICE LATERAL – 4".**

**B.**

**CLARIFICATION THAT CONTRACTOR SHALL COORDINATE WITH ROSWELL LIVESTOCK AUCTION SALES ACCESS INCLUDING WEEKENDS FOR LIVESTOCK TRAILERS AND CUSTOMERS. CONTRACTOR MUST KEEP ONE MAJOR DRIVEWAY OPEN AT ALL TIMES. STATION 33+75 LEFT AND/OR STATION 40+00.**

---

All other provisions of the contract documents shall remain unchanged. This addendum is hereby made a part of the Contract Documents to the same extent as those provisions contained in the original documents and all itemized listings thereof.

By: City of Roswell

A handwritten signature in blue ink that reads 'Casey Booth'.

---

Casey Booth, Interim Purchasing Agent, C.P.O.

A handwritten signature in black ink that reads 'Louis Najjar'.

---

Louis Najjar, City Engineer